

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190346
Address: 4508 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Partial	Tuesday, June 18, 2019

Corrective Action Required:

1	Misc	-fire block dead space at top plate east side, next to garage wall -support plumbing in garage every 4', drain line on north side of garage -ok to insulate
---	------	---

Comments: