

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191386  
Address: 2601 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Mark Harding	Failed	Tuesday, June 18, 2019

Corrective Action Required:

1	Misc	Failed- No address. --no erosion control. --filled in drainage swale at the rear with dig out . --no plans on site, AB showed up before i left. --missing grade beam footing at front of stairs in basement.
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**