

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172511
Address: 221 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Failed	Tuesday, June 18, 2019

Corrective Action Required:

1	LOWER LEVEL	Laudry drain pipe distance to drain. replace studs at laundry where removed corridor wall. Plumbing protection plates throughout. north exit - support , install joist hangers and hurrican ties as required on truss , check bearing at end soffit. joist hager all landing joist throughout.
---	-------------	---

Corrective Action Required:

2	FIRST FLOOR	Plumbing protection plates throughout
---	-------------	---------------------------------------

Corrective Action Required:

3	SECOND FLOOR	Plumbing protection plates throughout. shear wall nailing NW section 2nd room from the north.
---	--------------	--

Comments: