

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191417
Address: 4716 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, June 19, 2019

Corrective Action Required:

1	Misc	-FIREBLOCK STAIR WALL SPACE (WALL SPACE BETWEEN STAIR AND BASEMENT RECREATION AREA) FROM FURDOWN SPACE AND VERTICALLY AT TEN FT OR LESS
---	------	---

Comments: