

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183264
Address: 833 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Thursday, June 20, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY **UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT UPPER LEVEL.** ENSURE PRESSURE-TESTING OF PIPING SYSTEM IS PERFORMED PER IPC 312 / IRC P2503.5.1

Comments: