

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

June 20, 2019

DESIGN CLUB INC
30519 S LONETREE ROAD
HARRISONVILLE, MO 64701

Permit No: PRCOM20191251
Project Title: HALLAM PHASE 2 SHELL ADDITION
Project Address: 1225 NE DOUGLAS ST, LEES SUMMIT, MO 64086
Parcel Number: 52910150400000000
Location / Legal: MAPLE TREE PLAZA 2ND PLAT---LOT 3 (EX PT IN ROW)
Description:
Type of Work: ADDITION COMMERCIAL
Occupancy Group: UNCLASSIFIED
Description: SHELL ADDITION TO EXISTING BUILDING

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2018 IFC 408.11.2 - Tenant identification. Each occupied tenant space provided with a secondary exit to the exterior or exit corridor shall be provided with tenant identification by business name and/or address. Letters and numbers shall be posted on the corridor side of the door, be plainly legible and shall contrast with their background.

ACTION REQUIRED: (verified at inspection)

All rooms, offices and aux/spaces shall be labeled with the room use. Labeling shall be readable from hallways or corridors.

2. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: (verified at inspection)

Office spaces on the lower level shall have the front and rear doors addressed. Addressing shall be readable from the roadway. Offices spaces on the upper level shall have suite designation at each door. Lower level stairway door shall have a legend indicating which suites are accessible on the upper level.

DEVELOPMENT SERVICES

3. 2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

ACTION REQUIRED: (verified at inspection)

NO keyed lock cylinder locks on the egress side (interior) of an exit.

4. 2018 IFC 1008.1 Illumination required. The means of egress, shall be illuminated at all times the building space served by the means of egress is occupied.

ACTION REQUIRED: (Verified At Inspection)

Provide emergency lighting for the interior stairway

5. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

ACTION REQUIRED: (verified at inspection)

Provide one 2A-10BC fire extinguisher (5 pound) for each lower level office space and one 2A-10BC fire extinguisher (5 pound) for the upper level area. The extinguishers are to be mounted on a wall or in a extinguisher cabinet on a normal path of travel close to an exit.

Building Plan Review

Reviewed By: Joe Frogge

Rejected

4. Copies of the engineered truss package were not provided at the time of permit application.

Action required: Provide floor and roof truss packages or request deferral.

6/20/19 - deferred per request.

5. 2018 IBC 602.1 General. Buildings and structures erected or to be erected, altered or extended in height or area shall be classified in one of the five construction types defined in Sections 602.2 through 602.5. the building elements shall have a fire-resistance rating not less than that specified in Table 601 and exterior walls shall have a fire resistance rating not less than that specified in Table 602. Where required to have a fire-resistance rating by Table 601, building elements shall comply with the applicable provisions of Section 703.2. The protection for openings, ducts and air transfer openings in building elements shall not be required unless required by other provisions of this code.

Action required: Specify fire rating for exterior walls based on proximity to property line. Provide UL# and complete construction details.

6/20/19 - CMR denied. "1225 property has no control over what may or may not happen in the future on 1255 property."

Licensed Contractors

Reviewed By: Joe Frogge

Approved

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.