

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20183167  
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Fire Line - Hydrostatic Test</b>	Joe Starlin	Passed	Thursday, June 20, 2019

Informational:

1 Misc

6-20-19 we are testing the fire line for building 5 and 4.

Informational:

2 Misc

6-20-19 We are testing the fire line for building 5 and 4 at 200 psi for 2 hours. The fire line for building 4 and 5 held for 2 hours at 200psi.

**Comments:**