

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

June 19, 2019

NEIGHBORS CONSTRUCTION COMPANY INC 15226 W 87TH ST PARKWAY LENEXA, KS 66219

Permit No: PRCOM20191238
Project Title: ZEN MASSAGE

Project Address: 306 SW BLUE PKWY, LEES SUMMIT, MO 64063

Parcel Number: 61410197200000000

Location: SEC-07 TWP-47 RNG-31---TH PT S 1/2 NE 1/4 DAF: BEG 46.59' E OF SW COR LOT 2 STEVENSON

ADD TH S 102' TH SLY PARA WI W ROW LI SD ST 325' TO PT ON NLY ROW LI HWY 50 TH WLY ALG NELY ROW LI SD HWY 200' MOL ST TH NELY & NLY ALG CURV TO LF 300' MOL TO SW COR

LOT 117 BAYLES ADD TH E 280' TO W ROW LI MISSION

Type of Work: CHANGE OF TENANT

Occupancy Group: BUSINESS

Description: TENANT FINISH FOR MASSAGE BUSINESS

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200 Fire Department (816) 969-1300

Fire Plan Review Reviewed By: Joe Dir Approved with Conditions

1. 2018 IFC 408.11.2 - Tenant identification. Each occupied tenant space provided with a secondary exit to the exterior or exit corridor shall be provided with tenant identification by business name and/or address. Letters and numbers shall be posted on the corridor side of the door, be plainly legible and shall contrast with their background.

ACTION REQUIRED: (verified at inspection)

All rooms shall be identified with the type of room use. Room identifiaction shall be readable from the corridor. Storage, utility room, massage room etc.

2. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: (verified at inspection)

Front and rear door addressing shall be readable from the roadway. Interior business door off the the rear common area shall be addressed.

3. 2018 IFC 907.3.1 Duct smoke detectors. Smoke detectors installed in ducts shall be listed for the air velocity, temperature and humidity present in the duct. Duct smoke detectors shall be connected to the building's fire alarm control unit when a fire alarm system is rquired by Section 907.2. Activation of a duct smoke detector shall initiate a visible and audible supervisory signal at a constantly attended location and shall perform the intended fire safety function in accordance with theis code and the International Mechanical Code. Duct smoke detectors shall not be used as a substitute for required open area detection.

ACTION REQUIRED: Duct detection required to be installed. Include remote test switches with audible alarms.

4. 2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

ACTION REQUIRED:(verified at inspection)

No keyed locks on the egress side (interior) of an exit.

Building Plan Review Reviewed By: Joe Frogge Approved with Conditions

1. 2018 IBC 1109.12.3 – Point of sale and service counters. Where counters are provided for sales or distribution of goods or services, at least one of each type provided shall be accessible. Where such counters are dispersed throughout the building or facility, accessible counters shall also be dispersed.

Action required: Provide minimum 36" wide section of counter that is no taller than 36".

5/24/19 - Architect's letter states that the tenant has , per business plan, instructions to provide individual help to those in need.

Licensed Contractors	Reviewed By: Joe Frogge	Approved	
Approved to issue p	er the listed conditions.		
Do not issue per the	listed conditions.		
Approved to constru	uct foundation only per the listed conditions		
Requires Final Devel	lopment Plan approval prior to issuing this b	uilding permit.	
and Ordinances.			
Signature of Applicant	Date		
 Print Applicant Name	CompanyName		

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.