

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20180820  
Address: 4071 NE TIMBERLAKE CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Friday, June 21, 2019

Corrective Action Required:

1	Misc	-Submit the engineer letter for the footing piers -Drive way not approved on record -Secure AC whip -Self closing garage door required -Secure LFNC raceway below kitchen sink per code -Install gfci for hydrotub to wall surface -Remove insulation paper facing -Install rear light
---	------	---

**Comments:**