

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191446
Address: 410C SE 3RD ST, Unit:107, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Passed	Monday, June 24, 2019

Comments: NO REMAINING ISSUES ON WALL FRAMING OR IN-WALL SYSTEMS. ALSO, NO SIGNIFICANT ISSUES FOUND ON ABOVE-CEILING SYSTEMS WHERE TILE HAS BEEN REMOVED. OK TO COVER WALLS AND CEILING WHEN READY.

NOTE: RESTROOM IS REQUIRED TO BE HANDICAPPED ACCESSIBLE PER DRAWING. SEVERAL CORRECTIONS WILL BE REQUIRED BEFORE REQUESTING OCCUPANCY INSPECTION. SEE IPC, IBC 117.1, AND APPROVED DRAWING.