

David P. Ainsworth, P.E.
P.O. Box 597, Buckner, MO 64016
Cell Phone: 816-682-2093
Email: dainsworth@chelepis.com

June 21, 2019

Mr. Duane Hatton
Gary's Foundations
1207 S. Powell Rd.
Independence, MO 64057

Re: Property @
4713 NE Saratoga Ct.
Lee's Summit, MO
Permit # 2019-1516

Dear Mr. Hatton:

On June 20, 2019, I inspected the footing subgrade, forming and reinforcement steel placement for the foundation footings at the above referenced property. Probes with a penetrometer indicated soil bearing capacities in excess of the assumed 2,000 psf. Forms were properly aligned and braced and reinforcement steel was properly installed including UFER rods.

The foundation footings are approved for concrete footing placement.

Cordially



David P. Ainsworth, P.E.

