

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20183167  
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Hydrostatic Test</b>	Joe Starlin	Partial	Monday, June 24, 2019

Informational:

1 Misc

6-24-19 8:25am Test has started for building 4. 9:00am The test for the clubhouse has started. The line for building 4 has passed it held at 150 for two hours. 11:00am The waterline for the club house has passed it held for two hours at 150.

**Comments:**