

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183167
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Fire Line - Hydrostatic Test	Joe Starlin	Passed	Monday, June 24, 2019

Informational:

1	Misc	6-24-19 8:40am test is started for fireline for building 1,2,3 and clubhouse.
---	------	---

Informational:

2	Misc	6-24-19 8:40am test is started for fireline for building 1,2,3 and clubhouse. The line had a leak so we restarted the test. 12:05pm. The fireline has passed. It. Held for two hours at 200.
---	------	--

Comments: