

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191010  
Address: 4011 SW MERITAGE LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - Residential</b>	Brandon Kalwei	Failed	Monday, June 24, 2019

Corrective Action Required:

1	Misc	-piping not on adequate gravel -pit full of water, could not see connection
---	------	--

**Comments:**