

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183265
Address: 901 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Tuesday, June 25, 2019

Partial Correction:

1 Misc

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, &
VENT PIPING AT: LOWER LEVEL; **UPPER LEVEL**

ENSURE PRESSURE-TESTING OF PIPING SYSTEM IS PERFORMED PER IPC 312 /
IRC P2503.5.1

Partial Correction:

2 Misc

**OK TO COVER RADON MITIGATION PIPE AT UPPER LEVEL AFTER OPEN PORTS
AT TWO TEES ARE SEALED AGAINST ENTRY BY CONCRETE**

Comments: