

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRLD20190454
Address: 300 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	Steve Conrick	Partial	Tuesday, June 25, 2019

Comments:

Construcion entrance at obrien needs cleaned out and more rock. Construction entrance near north pond needs to be installed. Mulch berms need to be installed at north pond.