

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191010
Address: 4011 SW MERITAGE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Residential	Jason McRoy	Failed	Wednesday, June 26, 2019

Corrective Action Required:

1	Misc	CITY OF LS REQUIRES 10' OF COPPEER ON THE HOUSE SIDE OF THE METER. METER IS JUST UNDER 14" NEEDS TO BE BETWEEN 14" AND 18"
---	------	--

Comments: