

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20190589	Date:	June 26, 2019
Project Title:	OUR LADY OF PRESENTATION - CLASSROOM ADDITION	Applicant:	
Location:		AMERICAN FIRE SPRINKLER CORPORATION	
150 NW MURRAY RD, LEES SUMMIT, MO 64081		PO BOX 958	
Type of Work:		MISSION , KS 66201	
Occupancy Group:	E	Primary:	(913) 722-6900
Description:	ADDITION OF 2ND AND 3RD FLOOR CLASSROOMS TO EXISTING CHURCH		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195E		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Action Required)

Call (816)969-1300 to schedule a hydrostatic test. Have a current inspection tag on the riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.