

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183577
Address: 2320 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer Construction Inspection	John Jackson	Partial	Wednesday, June 26, 2019

Informational:

1 Misc

Contractor installed approximately 161' of 4" SDR - 26 sanitary main. 42' of 8" encasement piping with 8x2 4" casing spacers. ICON supervisor will send pictures of 8x4 wye installation into exiting main. Contractor will send picture of sewer tie-in.

Comments: