

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20172649
Address: 4801 SW RAINTREE PKWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Jason McRoy	Passed	Thursday, June 27, 2019

Corrective Action Required:

1	Misc	panels are ok. race way to meter needs to be moved to other side of meter and secured. ok for kcpl service when raceway is moved.
---	------	---

Comments: