

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20182996  
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Sidewalk Inspection</b>	Joe Starlin	Partial	Thursday, June 27, 2019

Informational:

1	Misc	6-27-19 3:30pm They have set up the sidewalk and are aware to stay in spec. They have poured almost all of the walk. The cure they laid down was inconsistent and light. I asked them to apply more cure. The temperature outside is 89 degrees with full sun. They pulled the forms without waiting so I asked them to cure the sides of the sidewalk as well. They did so but with attitude.
---	------	--

**Comments:**