

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191464
Address: 1112 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Residential	Khanh Nguyen	Partial	Friday, June 28, 2019

Partial Correction:

1 Misc

OK TO COVER PEX WATER LINE FROM BUILDING ENTRY AT NE CORNER OF HOUSE TO NEAR SE CORNER.

WATER LINE TAP NOT COMPLETED BY LSWU DUE TO MAIN NOT ACTIVE. TAP, BORE, EXTENSION TO METER LOCATION NOT COMPLETED PRESENTLY. CALL FOR INSPECTION WHEN TAP, PEX AND COPPER PIPING, AND METER WELL ARE COMPLETED AND EXPOSED FOR INSPECTION.

Comments: