

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191352
Address: 1305 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	John Borns	Passed	Friday, June 28, 2019

Comments: OK TO POUR WHEN READY WALL FOOTINGS & ISOLATED FOOTINGS. UFER GROUNDING JUMPER IS IN PLACE AT EAST WALL.