

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20183913

Address: 1420 NE DOUGLAS ST, LEES SUMMIT, MO 640861430 NE DOUGLAS ST, LEES SUMMIT, MO  
640861440 NE DOUGLAS ST, LEES SUMMIT, MO 640861410 NE DOUGLAS ST, LEES  
SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Driveway Inspection</b>	Joe Starlin	Partial	Friday, June 28, 2019

Informational:

1 Misc

The approach is ready for pour. Aggregate is compacted and pins are set for ADA compliance. They were told to use white cure.

**Comments:**