## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

## **Inspection Summary**

 Permit #:
 PRCOM20191276

 Address:
 205 SE M 291 HWY, LEES SUMMIT, MO 64063201 SE M 291 HWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mike Copeland	Partial	Tuesday, July 02, 2019
Partial Correction:	201 unit screws every	6" on seams and 12" field	okay to tang mud 201 side

1Miscellaneous201 unit screws every 6" on seams and 12" field. okay to tape mud 201 side<br/>only.1Correctiononly.

**Comments:**