

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20190679	Date:	July 02, 2019
Project Title:	REECE NICHOLS 2	Applicant:	
Location:			
222 SW MAIN ST, LEES SUMMIT, MO 64063		PROGRESSIVE ELECTRONICS INC	
Type of Work:		6102 ARLINGTON AVE	
Occupancy Group:	B	RAYTOWN, MO 64133	
Description:	OFFICE BUILDING FOR REAL	Primary: (816) 765-5750	
ESTATE BUSINESS			
FOUNDATION PERMIT - PRCOM20191085			
Construction Type:	Type VB (Unprotected)		
Map Page:	195F		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Action Required)

Call (816)969-1300 to schedule testing for the fire alarm system.

2. (Action Required)

Strobe in second floor corridor, replace with horn/strobe. Correction has been made on plans.

3. (Informational Purposes)

Address for building is 222 SW Main St.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**