

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20170409

Address: 3570 SW HOLLYWOOD DR, Unit:7, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Brandon Kalwei	Failed	Wednesday, July 03, 2019

Corrective Action Required:

1	Misc	307-Back to back low voltage, verify distance with box manufacture and UL. 306-hold down screw north wall kit. Verify with 3rd party inspector. 308-10' Fire stop party walls. 309-4" DWV fire collar-party wall. 311-South bathroom sub floor no backing under plywood. 310- 10' Fire stopping at party walls.
---	------	--

Comments: