

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190494  
Address: 2512 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Failed	Wednesday, July 03, 2019

Corrective Action Required:

1 Misc

- \*\*Cut waterlines over kitchen.
- \*\*install two studs under LVL top of stair landing.
- \*\*Provide fall for roof vents.
- \*\*Secure ward flex at fireplace .
- \*\*\*Wall bracing over landing to top plate second floor see plan or verify with architect.
- \*\*bond metal pan cake box at front garage walls and ceiling boxes.

Comments: