

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20172511  
Address: 221 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Not Ready	Wednesday, July 03, 2019

Corrective Action Required:  
1 SECOND FLOOR RC:  
  
UNITS:  
  
PREROCK: ok  
tubs

Corrective Action Required:  
2 FIRST FLOOR RC:  
  
UNITS:  
  
PRE-ROCK: ok  
tubs

Corrective Action Required:  
3 LOWER LEVEL RC:  
  
UNITS:  
  
PRE-ROCK: ok  
tubs

Corrective Action Required:

4

Misc

fire collars on 4" dwv in 4 units  
all levels incomplete for the #3rd time.  
fees due for the 3rd and 4th inspections.

**Comments:**