

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20183200  
Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Failed	Wednesday, July 03, 2019

Corrective Action Required:

1	Misc	TRUSS DRAWINGS FOR TRUSSES SHOWN ON LAYOUT FOR EAST WING NOT FOUND IN SET. EXAMPLES: T10-T21 + OTHERS
---	------	--

ALSO, ENSURE DIAGONAL BRACING IS COMPLETED AS SHOWN ON DETAIL (9), DRAWING SHEET A0.1

CALL FOR RE-INSPECTION WHEN ABOVE ARE READY.

**Comments:**