

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183842
Address: 104 SW MEADOWBROOK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Friday, July 05, 2019

Corrective Action Required:

1	Misc	Install spark rings at outlets located in tile backsplash in kitchen. Install spark ring at outlet in tile in master bath. Install spark rings at outlets in tile backsplash in basement bar. Final grading. Sod Discharge sump min 36" away from foundation.
---	------	--

Comments: