

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183649
Address: 4505 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Jason McRoy	Failed	Friday, July 05, 2019

Corrective Action Required:

1	Misc	Strap top plate in master bedroom above pocket door. Strap top plates above left of sliding glass doors in dining area. Install lug at electric panel for gas line bonding conductor.
---	------	---

OK TO INSULATE

Comments: