

Inspection Summary

Permit #: PRSITE20191463, Development - Site

Goddard School - Chapel Ridge

Address: 3301 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Grading/Excavation/Fill Inspection Informational	John Jackson	Partial	Monday, July 08, 2019
1	Goddard School contractor continued to grade site and install construction entrance .		

Comments: