

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183262
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	John Borns	Failed	Wednesday, July 10, 2019

Corrective Action Required:

1	Misc	#6 COPPER BONDING RING NOT FOUND INSTALLED AT SPA DECK AS DISCUSSED. CALL FOR INSPECTION 7:00 - 5:00 FOLLOWING DAY WHEN READY.
---	------	--

Comments: