

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20184041  
Address: 4067 NE TIMBERLAKE CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Wednesday, July 10, 2019

Corrective Action Required:

1	Misc	-Final grade, sod, splash blocks -Security strike plate for exterior door -Garage door closer -Basement walkout door: fill gap behind hinges with solid wood -Protect wiring across bottom of joists -Remove all foundation wall steel ties -Support duct below front bedroom
---	------	---

**Comments:**