CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183262 Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Monday, July 15, 2019
Partial Correction:			
1 Misc	OK TO COVER WHEN READY TRENCHED ELECTRICAL CONDUIT AT: THREE TWO 1-1/4" OUTSIDE WEST WALL OF BLDG 1 LEFT WING; SAME CLUSTEF CODUIT APPROVED 140 FEET SOUTH TO 90 EAST TO (C); + 50' EAST TO (E THREE 4" FROM (C) TO (D); THREE 4" + TWO 1-1/4" FROM (E) TO (F); THR TWO 1-1/4" + ONE 3/4" FROM (F) TO (G); ONE 1-1/4" FROM (H) TO (I); O 1-1/4" + TWO 3/4" FROM (I) TO (J); ONE 3/4" STUBBED EAST FROM (J); T 3/4" FROM (J) TO (K); TWO 3/4" FROM (K) TO (L); THREE 4" + TWO 1-1/4" 3/4" FROM (G) TO (M); THREE 4" + TWO 1-1/4" + TWO 3/4" FROM (M) TO WITH ONE STUBBED WEST AT (M) FOR SITE LIGHTING; TWO 4" + TWO 1- ONE 3/4" FROM (G) TO (M); THREE 4" + TWO 1-1/4" + ONE 3/4" FROM (Q) TO (R) 3/4" FROM (T) TO (U); 3/4" CONDUIT AT CONSTRUCTION ENTRANCE APPROVED; 3/4" CONDUIT 110 FEET FROM SE CORNER OF THE BUILDING REMAINDER OF RUN TO VAULT AT (W); THREE 4" + TWO 1-1/4" FROM (N (X); THREE 4" + THREE 1-1/4" FROM (X) TO (Y); FOUR 4" + ONE 3/4" (AA); ONE 3/4" AT ISLAND @ (W); ONE 3/4" FROM (X) TO (BB); ONE 3/4" (X) TO (CC); FOUR 4" + ONE 3" FROM (CC) TO (DD); THREE 4" + TWO 1-1/4 FROM (HH) TO 60' WEST @ (II); THREE 4" + ONE 1-1/4" FROM (JJ) TO (KK THREE 4" + THREE 1-1/4" + ONE 3/4" FROM (LL) TO (MM) - THEN 30' EAS THREE 4" + THREE 1-1/4" + ONE 3/4" FROM (LL) TO (MM) - THEN 30' EAS THREE 4" + THREE 1-1/4" + ONE 3/4" FROM (LL) TO (MM) - THEN 30' EAS		LEFT WING; SAME CLUSTER OF AST TO (C); + 50' EAST TO (E); -1/4" FROM (E) TO (F); THREE 4" + E 1-1/4" FROM (H) TO (I); ONE STUBBED EAST FROM (J); TWO (L); THREE 4" + TWO 1-1/4" + ONE I" + TWO 3/4" FROM (M) TO (N) GHTING; TWO 4" + TWO 1-1/4" + 1-1/4" + ONE 3/4" FROM (N) TO ONE 3/4" FROM (Q) TO (R); ONE STRUCTION ENTRANCE CORNER OF THE BUILDING; E 4" + TWO 1-1/4" FROM (M) TO ; FOUR 4" + ONE 3" FROM (Z) TO ROM (X) TO (BB); ONE 3/4" (FROM (DD); THREE 4" + TWO 1-1/4" (HH); ONE 1-1/4" + ONE 3/4" NE 1-1/4" FROM (JJ) TO (KK); L) TO (MM) - THEN 30' EAST;
		·1/4 TONE 5/4 FRONI (L	$L_1 \cup (ININ) \cup U \cup U \cup I \cup I \cup I \cup KEE 4 +$

ONE 1-1/4" ORIGINATING FROM (KK) EXTENDED TO (NN); REMAINDER OF CONDUITS FROM E/SE CONVERGING ON LOCATION OF BOX TO BE INSTALLED AT (II); FOUR 4" + ONE 3" FROM XFMR LOCATION TO W END OF BLDG 4; THREE 4" FROM E END OF BLDG 4 NORTH 35', THEN S 15' TO (OO); FROM MONUMENT SIGN AT NORTH ENTRANCE TWO 3/4" TO 30' SE & TWO 3/4" TO 30' SW; FOUR 4" + ONE 3" FROM (OO) TO (PP) & SECONDARY CONDUITS AT (PP);

SECONDARY SERVICE CONDUITS FROM TRANSFORMER LOCATION TO BLDG: BLDG 1 - FOUR 4" + ONE 3"; THREE SECONDARY 4" FROM (V) TO 24' EAST @ BLDG 1; BLDG 2 - FOUR 4" @ SO END + THREE 4" @ N END;

LOCATIONS (X) REFERENCED ARE NOTED ON INSPECTOR'S COPY OF SITE ELECTRICAL PLAN.

EAST SIDE MAIN BUILDING: 3 4" SECONDARY 1 4" PRIMARY APPROVED

BUILDING 5 SECONDARY CONDUITS APPROVED

Comments: