

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190414
Address: 2404 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Monday, July 15, 2019

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- fire stop throughout.- fire stop box in 2nd bedroom.- firestop basement walls, fur downs, drop ceiling, where i beams meet fur downs, dead space angle wall in bsmt.- flue clearance at 1st floor.- secure gas line at fire place.-plans show 2x6 rear basment exterior wall revise plans or provide engineer report.
---	------	--

Comments: