

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190414  
Address: 2404 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Failed	Monday, July 15, 2019

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- fire stop throughout.</li><li>- fire stop box in 2nd bedroom.</li><li>- firestop basement walls, fur downs, drop ceiling, where i beams meet fur downs, dead space angle wall in bsmt.</li><li>- flue clearance at 1st floor.</li><li>- secure gas line at fire place.</li><li>-plans show 2x6 rear basment exterior wall revise plans or provide engineer report.</li></ul>
---	------	--

Comments: