

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183471
Address: 420 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Steve Robbins	Passed	Tuesday, July 16, 2019

Informational:
1 Misc 5-28-19 The forms are set and the drive is 36' wide. Aggregate is in and compacted. Ready for pour.

Informational:
2 Misc 7-16-19 The driveway is poured and meets spec.

Comments: