

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20174026
Address: 2801 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Thrust Restraint	John Jackson	Partial	Friday, June 07, 2019

Informational:

1

Thrust block were poured for the two 8"x6" tees and a straddle block on the 6" and 6" reduce 4" lines coming out of the DIP Tees. Thrust blocks were poured behind hydrant assembly.

Comments: