

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20180854
Address: 4720 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Not Ready	Wednesday, July 17, 2019

Corrective Action Required:
1 Misc

-Window glazing within 24" of the rear patio door must be safety tempered.

NO CHANGE MADE TO GLAZING. \$50 NOT READY FEE. MUST BE PAID FOR ANY OCCUPANCY.

Comments: