

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

July 17, 2019

MUDLOFF CONSTRUCTION LLC
1917 E SPRUCE ST
OLATHE, KS 66062

Permit No: PRCOM20191742
Project Title: CODE NINJA
Project Address: 314 SW BLUE PKWY, LEES SUMMIT, MO 64063
Parcel Number: 61410197200000000
Location: SEC-07 TWP-47 RNG-31---TH PT S 1/2 NE 1/4 DAF: BEG 46.59' E OF SW COR LOT 2 STEVENSON
ADD TH S 102' TH SLY PARA WI W ROW LI SD ST 325' TO PT ON NLY ROW LI HWY 50 TH WLY
ALG NELY ROW LI SD HWY 200' MOL ST TH NELY & NLY ALG CURV TO LF 300' MOL TO SW COR
LOT 117 BAYLES ADD TH E 280' TO W ROW LI MISSION
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: TENANT FINISH FOR TEACHING COMPUTER CLASSES

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)

Address front and back doors 314

2. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(Verified At Inspection)

Provide one 2A10BC Extiguisher

3. 2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

(Verified At Inspection)

Building Plan Review

Reviewed By: Joe Frogge

Approved

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

- ☒ Approved to issue per the listed conditions.
☐ Do not issue per the listed conditions.
☐ Approved to construct foundation only per the listed conditions.
☐ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.