

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191238
Address: 306 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Thursday, July 18, 2019

Partial Correction:

1	Misc	OK TO COVER EXCEPT AT FERNCO CONNECTION TO MAIN BUILDING DRAIN. REPLACE WITH STIFFBACK.
---	------	---

Comments: