

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190414
Address: 2404 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|-------------------------|
| All Rough Inspection - Residential | Mark Harding | Failed | Thursday, July 18, 2019 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -plans show 2x6 rear basement exterior wall revise plans or provide engineer report. |
| | | Locate Ufer ground - attempt to locate location , contact Foundation contractor and or use window cut out for steel |

Comments: