CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20184050

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

DE - Street - Proof Roll John DiMauro Passed Friday, July 19, 2019

Informational:

1 Misc I observed the proof roll for the fly ash treated subgrade for the subdivision.

I verified the correct truck type and load weight. The proof roll passed

inspection.

Comments: