

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191460  
Address: 1160 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	John Borns	Passed	Friday, July 19, 2019

**Comments: OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING COMPLETE.**

**REVISED ENGINEER DRAWING TO BE SUBMITTED TO REFLECT SIGNIFICANT MODIFICATION OF BUILDING DRAIN CONFIGURATION**