

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183842
Address: 104 SW MEADOWBROOK DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Friday, July 19, 2019

Corrective Action Required:

1	Misc	Need a clean out for the sewer stub in basement by electrical panel, currently has a cap on it Connect furnace piping that is coming apart in furnace room Final grading. Sod Discharge sump min 36" away from foundation.
---	------	--

Comments: