

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20170409

Address: 3570 SW HOLLYWOOD DR, Unit:7, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Brandon Kalwei	Failed	Monday, July 22, 2019

Corrective Action Required:

1	Misc	Tie down in room 211 south side just inside bedroom on left side Fire block penetration on floor in room 211, right side of bedroom Support strap for duct work cut in room 208, needs to be properly supported
---	------	---

**Comments:**