

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20180219  
Address: 201 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Coliform Test 1</b>	Ronald Paynter	Partial	Tuesday, July 23, 2019

Informational:  
1 Misc There was no Bac-T test performed here yet. I opened the wrong address inspection. RP 5-23-19

Informational:  
2 Misc Lief chlorinated the water line to 100 parts per million. We will dechlorinate the line tomorrow at 8:30am. RP 7-23-19

**Comments:**