

PLANS REVIEW CONDITIONS

Permit No: PRCOM20191480	Date: July 23, 2019
Project Title: LEE'S SUMMIT MEDICAL CENTER PHARMACY RENOVATIONS	Applicant:
Location: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063	Siemens Industry, Inc. 8066 Flint Street Lenexa , KS 66214
Type of Work:	
Occupancy Group: I-2	
Description: RENOVATIONS TO PHARMACY IN EXISTING HOSPITAL	
Construction Type: Type IB	
Map Page: 196K	

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a fire alarm test. Life safety must pass before a final can be scheduled.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.